## Questions and Answers for HVAC Controls RFB

- 1. Does the bid have to be in the office by April 28, no but they need to be post marked by April 28.
- 2. Does all of the sensors and transmitters need to be replaced, no only the nonoperational, or ones that will not work with your system.

## Section C: Controls scope of work

3. "2. Retrofit the existing mechanical controls in the building for HVAC System (air handling units, boilers, chiller, cooling tower, zone introduction units and unit heaters"

**Question**: Are the DDC controls for all the 96 VAV boxes and 4 unit heaters to be replaced? Please verify quantities.

Only replace if device if it has failed or not compatible with your system. 96 VAV boxes and 4 unit heaters

4. "11. Install flow switches on boilers 1 & 2"

**Question:** Are flow switches currently not installed?

Switches are not installed

5. "21. Program fan terminal units 4 each into the control system"

**Question:** Where are these 4 units located and are they not on the current DDC system? Basement,  $1^{st}$  floor,  $2^{nd}$  floor, and  $3^{rd}$  floor

## Section F: Schedule of work

- Is work during library operation hours approved?
  Only if it does not interfere with library operation, no hot or cold building do to system being down
- 7. Is there a bond requirement? No you must have insurance

## Attachment 4: Customer Reference Worksheet

8. Are customer reference required to use the library's worksheet? Yes but if you want to submit your own you can do that as well.